

COASTSIDE FIRE PROTECTION DISTRICT

REPORT OF FIRE SAFETY INSPECTION

<u>Requirements</u>		<u>Code Section</u>
<u>PERMITS/LICENSES</u>		
<input type="checkbox"/>	<input type="checkbox"/> 1.1	Apply for permit from Fire Prevention for (see comments) C.F.C. 105.6
<input type="checkbox"/>	<input type="checkbox"/> 1.2	Apply for permit from Building Dept. for new construction or electrical system changes C.B.C. 105.1
<u>PREMISES IDENTIFICATION AND ACCESS</u>		
<input type="checkbox"/>	<input type="checkbox"/> 2.1	Install approved address numbers in an approved location C.F.C. 505.1
<input type="checkbox"/>	<input type="checkbox"/> 2.2	Provide an approved Key Box on building exterior C.F.C. 506
<input type="checkbox"/>	<input type="checkbox"/> 2.3	Discontinue obstructing the fire lane(s) C.F.C. 503.4
<input type="checkbox"/>	<input type="checkbox"/> 2.4	Provide approved fire lane signs. Paint curbs red. C.F.C. 503.3
<input type="checkbox"/>	<input type="checkbox"/> 2.5	Provide sign THIS DOOR BLOCKED on exterior of building (6" letters 3/4" stroke) C.F.C. 504.2
<u>EXITS</u>		
<input type="checkbox"/>	<input type="checkbox"/> 3.1	Provide and maintain unobstructed exit doors and exit paths C.F.C. 1003.3.4/1003.6
<input type="checkbox"/>	<input type="checkbox"/> 3.2	Provide maximum occupancy load sign T19 3.30
<input type="checkbox"/>	<input type="checkbox"/> 3.3	Remove locking device(s) from exit doors C.F.C. 1008.1.9.3
<input type="checkbox"/>	<input type="checkbox"/> 3.4	Unlock all exit doors during business hours C.F.C. 1008.1.9.3
<input type="checkbox"/>	<input type="checkbox"/> 3.5	Provide sign above exit door "This door to remain unlocked when building is occupied" C.F.C. 1010.1.9.3
<input type="checkbox"/>	<input type="checkbox"/> 3.6	Install an exit sign above exit door, 6" high with 3/4" stroke C.F.C. 1011.6.1
<input type="checkbox"/>	<input type="checkbox"/> 3.7	Repair, provide or replace approved illuminated exit signs C.F.C. 1013
<u>FIRE EXTINGUISHERS</u>		
<input type="checkbox"/>	<input type="checkbox"/> 4.1	Install type <u>2A10BC</u> fire extinguisher 3-5 ft above floor & accessible C.F.C. 906.1/T-19 567
<input type="checkbox"/>	<input type="checkbox"/> 4.2	Post sign(s) indicating the location of obscured fire extinguishers C.F.C. 906.6
<input type="checkbox"/>	<input type="checkbox"/> 4.3	Have extinguisher(s) serviced annually by a licensed company C.F.C. 906.2
<u>ELECTRICAL</u>		
<input type="checkbox"/>	<input type="checkbox"/> 5.1	Remove extension cord(s) used as permanent wiring C.F.C. 605.5
<input type="checkbox"/>	<input type="checkbox"/> 5.2	Remove or repair non-conforming electrical installation (refer to Bldg. Dept.) C.F.C. 605.1
<input type="checkbox"/>	<input type="checkbox"/> 5.3	Provide a minimum clearance of 30 inches around electrical panel C.F.C. 605.3
<input type="checkbox"/>	<input type="checkbox"/> 5.4	Provide approved fusible strip(s) which do not penetrate walls, doors, windows, etc. C.F.C. 605.4.1/4.3
<input type="checkbox"/>	<input type="checkbox"/> 5.5	Relocate or protect extension cords in order to prevent physical damage C.F.C. 605.5
<input type="checkbox"/>	<input type="checkbox"/> 5.6	In completed installations, each box shall have a cover, faceplate, or fixture canopy C.F.C. 605.6
<input type="checkbox"/>	<input type="checkbox"/> 5.7	Fusible strips must be plugged directly into wall outlet C.F.C. 605.4.2
<u>HOUSEKEEPING/STORAGE</u>		
<input type="checkbox"/>	<input type="checkbox"/> 6.1	Store oily rags in approved self-closing containers T-19 3.19
<input type="checkbox"/>	<input type="checkbox"/> 6.2	Remove storage from exits, corridors, exit enclosures, electrical rooms and attics C.F.C. 1003.6
<input type="checkbox"/>	<input type="checkbox"/> 6.3	Combustible storage shall be orderly & maintained clear of ceiling & sprinklers C.F.C. 315.3.1
<input type="checkbox"/>	<input type="checkbox"/> 6.4	Reduce storage height to 12 feet or less or contact Fire Prevention for high-piled storage permit C.F.C. 3201.2
<input type="checkbox"/>	<input type="checkbox"/> 6.5	Secure compressed gas cylinders to prevent physical damage C.F.C. 5304.1
<input type="checkbox"/>	<input type="checkbox"/> 6.6	Remove weeds, rubbish, vegetation that is dangerous to neighboring property or health T-19 3.07
<u>MAINTENANCE</u>		
<input type="checkbox"/>	<input type="checkbox"/> 7.1	Maintain all required fire-resistive construction (breached walls/ceilings) C.F.C. 703.1
<input type="checkbox"/>	<input type="checkbox"/> 7.2	Required fire rated passage doors must self close, seal and latch C.F.C. 703.2.3
<input type="checkbox"/>	<input type="checkbox"/> 7.3	Maintain all automatic closing fire doors/dampers C.F.C. 703.2.2
<input type="checkbox"/>	<input type="checkbox"/> 7.4	Flammable, decorative material must be flame resistive C.F.C. 807
<u>HAZARDOUS MATERIALS</u>		
<input type="checkbox"/>	<input type="checkbox"/> 8.1	Reduce quantities of hazardous materials or apply for permit C.F.C. 105.6.21
<input type="checkbox"/>	<input type="checkbox"/> 8.2	Separate stored materials that are incompatible C.F.C. 5003.87
<input type="checkbox"/>	<input type="checkbox"/> 8.3	Provide a system of transfer of flammable & combustible liquids C.F.C. 5705.1
<input type="checkbox"/>	<input type="checkbox"/> 8.4	Provide flammable liquid storage cabinet or reduce quantities C.F.C. 5003.8.7
<input type="checkbox"/>	<input type="checkbox"/> 8.5	Refrain from cleaning with flammable liquids C.F.C. 5705.3.6
<input type="checkbox"/>	<input type="checkbox"/> 8.6	Containers for mixing or dispensing Class I liquids shall be bonded C.F.C. 5706.5.1.7
<u>FIRE PROTECTION SYSTEMS/DETECTION SYSTEMS</u>		
<input type="checkbox"/>	<input type="checkbox"/> 9.1	Hood extinguishing system shall be serviced semi-annually and tagged C.F.C. 609.3.3.1
<input type="checkbox"/>	<input type="checkbox"/> 9.2	Hoods, grease removal devices, fans and ducts shall be cleaned frequently C.F.C. 609.3.3.2
<input type="checkbox"/>	<input type="checkbox"/> 9.3	Obtain 5 year certification of automatic sprinkler/standpipe system C.F.C. 901.6.1
<input type="checkbox"/>	<input type="checkbox"/> 9.4	Replace damaged heads and/or replace missing heads & wrench in sprinkler box C.F.C. 901.6
<input type="checkbox"/>	<input type="checkbox"/> 9.5	Maintain visibility and access to hydrants, FDC's, PIV's, Sprinkler Riser C.F.C. 912.4
<input type="checkbox"/>	<input type="checkbox"/> 9.6	Fire Protection or extinguishing systems shall be maintained in an operable condition at all times (smoke detectors, remove all paraphernalia from sprinkler heads and piping) C.F.C. 901.6/ T-19 3.24

Authority to conduct inspections by the Fire District is found in the 2016 California Fire Code Sec. 106 and the amendments thereto as adopted by the Coastside Fire District.